



NOTE:

1. . ALL SEGMENTS OF THE EAR MUST BE WELDED TOGETHER AND WELDED TO THE WALL
2. . CHECK SYSTEM SPEC FOR GUIDELINES ON ADHERING FLASHINGS.
3. . FOR INSULATION THICKNESS GREATER THAN 8" (203 mm), A COVER BOARD IS REQUIRED ON MECHANICALLY ATTACH SYSTEMS ONLY.

INSIDE CORNER 'PIG EAR' UP

Scale: N.T.S.